

Fire Protection Survey Services™

P.O. Box 170
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (249) 359-7231
E-mail: fpss@xplornet.ca Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: City of Kingston

ACCREDITED FIRE STATIONS

Fire Station #1 – Joyceville Rd.

Fire Station #2 – Brewers Mills Rd.

Fire Station #3 – Gore Rd.

Fire Station #8 – Unity Rd.

Fire Station #9 – Highway 38

Date Test Passed: September 29, 2018

Flow Achieved: 750 I.G.P.M. 3405 LITERS/MIN.

Two (2) Hour Test Time



Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.
Senior Partner
Senior Fire Protection Specialist
Senior Loss Control Specialist

This Certificate Expires on October 1, 2023